



To whom it may concern

ESSENTIAL INFORMATION - COMPOSITE FENCE PANELS AND SMOKE CONTROL SYSTEMS

We have recently been made aware of a number of incidents nationally where fires involving composite fence panels resulted in rapid fire spread, significant property damage and risk to life. This letter includes information on action that can be taken to address these concerns in order to reduce the risk.

This letter also highlights concerns around smoke control systems failing to operate correctly within residential buildings, such as blocks of flats. The failure of these systems has the potential to endanger the lives of both occupants and attending firefighters.

Composite Fence Panels

There have been a number of serious fires involving composite fence panels. The panels were ignited accidentally and the resultant fires spread rapidly and generated large volumes of acrid smoke. The two images below show the rapid fire spread and the aftermath of the fire.



The use of this type of fence panel is now becoming more widespread due to the perceived attractive appearance and low maintenance requirements, but there are a number of things which may not have been considered:

- Although the panels often look like wood, the behaviour of them in fire can be very different.



- The speed with which they burn is much faster and the heat and smoke released can be much greater than wood.
- Purchasers may believe that they will perform the same as timber products.
- Although it is possible to purchase fire resistant composite fencing panels, there are many that have little or no fire resistance.

The presence of composite fence panels (where applicable) should be addressed as part of your fire risk assessment. Consideration should be given to the external envelope of the building and the fire resistance of any composite panels present. You should ensure that adequate control measures have been implemented to manage those risks and reduce the risk from fire.

If you do have composite fence panels then you should:

- Ensure that all other aspects of your fire precautions are fully functioning such as your fire alarm, fire doors, etc.
- Consider if there is the potential for fire and smoke to spread into the wall system or into the premises.
- Consider who is at risk, if occupiers are vulnerable and/or require assistance to escape, could the fire or smoke from burning composite panel fencing prevent them from escaping in the event of a fire.
- Take action to reduce the potential for fire spread.
- Take action to prevent any sources of ignition.
- Consider replacing the flammable fence panels with fire resistant or wooden panels.
- Notify occupants and managers and make them aware of what they can do to reduce the risk of a fire.

If you chose to appoint a third party Fire Risk Assessor to carry out the assessment on your behalf, then you should take steps to ensure that the Fire Risk Assessor is competent. You can view advice on choosing a competent Risk Assessor on the Business Safety section of our website <https://www.cheshirefire.gov.uk/business-safety/choosing-a-competent-fire-risk-assessor>.

Smoke Control Systems in Blocks of Flats

There have been several incidents nationally where the smoke control systems protecting staircases (and/or adjacent corridors and lobbies) within residential blocks of flats have failed to operate as designed during a fire situation.

The systems are designed to ensure that heat and/or smoke generated in the event of a fire doesn't compromise the protected escape routes. They also ensure that these routes can continue to be used safely and support firefighting activities within the building.

Section 9 of the Ministry of Housing, Communities and Local Government document 'Advice for Building Owners of Multi-storey, Multi-occupied Residential Buildings' provides advice on smoke control systems.

Building owners should be aware of the type of smoke control system they have in place and how this is intended to control the spread of smoke in the event of fire. This should be



Cheshire

Fire & Rescue Service

available in original design information, but if it is not then building owners should seek professional advice to ascertain how it should function.

The standards for the maintenance and testing of smoke control systems are set out in BS EN 12101 and BS 9999:

- Smoke control systems should be tested weekly by the building owner to ensure that they are operating effectively, including fans or powered exhausts, dampers and door hold open/close devices.
- Every 3 months a full activation of the smoke control system should take place where each zone is checked individually.
- An annual inspection carried out by a suitably qualified person.

The correct operation of a smoke control system is essential to the safety of the occupants of a residential building, as well as improve the working conditions for the safety of firefighters. The effects of an incorrectly functioning system can spread smoke and fire throughout the building and prevent building occupants from escaping.

If you have any queries or questions regarding this letter then please contact our headquarters fire protection team on 01606 868700 or by email to fireadviceshq@cheshirefire.gov.uk.

Yours Sincerely

Lee Shears
Head of Prevention and Protection