

Listed Buildings

Inc No	Station Area	Time Of Call	Property Category	Property Type	Incident Category	Incident Type
2201000898	Chester	04/01/2022 03:24:20	NonResidential	Other	False Alarm	Fire alarm due to Apparatus >> Unknown
2201005418	Macclesfield	18/01/2022 13:45:54	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2202007203	Chester	22/02/2022 02:49:24	Dwelling	Up to 2 storeys	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2203003663	Macclesfield	10/03/2022 21:35:46	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Dust
2203005868	Congleton	16/03/2022 17:03:15	NonResidential	Community centre/Village or Parish Hall	Special Service	Medical Incident - First responder
2203009223	Winsford	23/03/2022 10:09:05	Dwelling	Up to 3 storeys	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2203010198	Frodsham	24/03/2022 23:37:48	NonResidential	Bank/Building Society	False Alarm	Fire alarm due to Apparatus >> Unknown
2203010299	Chester	25/03/2022 09:02:55	NonResidential	Law Courts	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2203010451	Winsford	25/03/2022 15:18:12	Dwelling	Up to 3 storeys	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2203013081	Macclesfield	30/03/2022 23:31:14	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2204000004	Holmes Chapel	01/04/2022 00:33:26	OtherResidential	Hotel/motel	Special Service	Lift Release
2204003141	Chester	09/04/2022 15:53:38	NonResidential	Other Restaurant/café - (licensed for sale of alcohol)	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2204005554	Lymm	15/04/2022 19:21:48	Dwelling	House - single occupancy	Fire	Derelict Building Fire - Deliberate cause
2204011177	Wilmslow	28/04/2022 13:07:05	NonResidential	Infant/primary school	False Alarm	Good Intent false alarm >> Fire >> Overheating appliance
2205002871	Wilmslow	08/05/2022 18:57:43	OtherResidential	Hotel/motel	Fire	Derelict Building Fire - Deliberate cause
2205003607	Macclesfield	10/05/2022 17:28:46	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2205008043	Northwich	21/05/2022 19:00:50	NonResidential	Pub/wine bar/bar	Special Service	Other assistance to police/ambulance
2205008065	Northwich	21/05/2022 19:43:18	OtherResidential	Nursing/Care	Special Service	Flooding
2205010533	Sandbach	28/05/2022 11:34:03	Dwelling	Up to 3 storeys	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2206000570	Congleton	02/06/2022 13:52:54	Dwelling	Up to 3 storeys	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2206003687	Macclesfield	10/06/2022 17:34:19	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2206003987	Nantwich	11/06/2022 15:39:32	NonResidential	Church/Chapel	Special Service	Medical Incident - First responder
2206006293	Chester	16/06/2022 14:43:49	NonResidential	Bank/Building Society	Special Service	No action (not false alarm)
2206006333	Chester	16/06/2022 16:23:50	NonResidential	College/University	False Alarm	Fire alarm due to Apparatus >> Unknown
2206006621	Macclesfield	17/06/2022 07:37:19	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2206006885	Chester	17/06/2022 18:46:56	NonResidential	Department Store	Special Service	Lift Release
2206007556	Crewe	19/06/2022 14:09:43	NonResidential	Converted office	Fire	Primary Fire - Deliberate cause
2206007636	Congleton	19/06/2022 16:35:43	OtherResidential	Nursing/Care	Special Service	Effecting entry/exit
2206009311	Knutsford	23/06/2022 02:02:03	OtherResidential	Nursing/Care	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2207003601	Chester	10/07/2022 02:29:40	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Water intrusion
2207003632	Macclesfield	10/07/2022 06:14:12	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2207008285	Chester	19/07/2022 02:23:58	OtherResidential	Hotel/motel	False Alarm	Malicious False Alarm >> Activation of fire call point/alarm
2207011022	Winsford	24/07/2022 06:16:19	OtherResidential	Children's	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2207013794	Powey Lane	31/07/2022 00:30:44	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2207013974	Macclesfield	31/07/2022 14:07:23	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2208000963	Macclesfield	03/08/2022 12:15:37	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2208002660	Knutsford	07/08/2022 17:35:22	NonResidential	Pub/wine bar/bar	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2208002897	Macclesfield	08/08/2022 10:55:19	NonResidential	Hospital	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2208003769	Macclesfield	09/08/2022 23:20:48	Dwelling	House - single occupancy	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2208004465	Macclesfield	11/08/2022 13:31:49	NonResidential	Purpose built office	Special Service	Lift Release
2208004688	Chester	11/08/2022 20:04:22	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: heat >> Faulty
2208007449	Macclesfield	15/08/2022 10:32:36	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2208009659	Macclesfield	20/08/2022 09:31:26	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: other >> Faulty
2208011071	Lymm	23/08/2022 17:16:17	Dwelling	Up to 2 storeys	Fire	Primary Fire - Deliberate cause
2208013578	Knutsford	29/08/2022 14:05:31	Dwelling	Stately Home	False Alarm	Fire alarm due to Apparatus >> Human >> Other

Listed Buildings

Inc No	Station Area	Time Of Call	Property Category	Property Type	Incident Category	Incident Type
2208013964	Chester	30/08/2022 12:02:05	NonResidential	Bank/Building Society	Special Service	Other assistance to police/ambulance
2209003861	Macclesfield	10/09/2022 18:27:54	NonResidential	Hospital	Special Service	Hazardous Materials incident
2209008666	Macclesfield	23/09/2022 13:13:32	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2209010564	Macclesfield	28/09/2022 16:16:45	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2210000397	Powey Lane	02/10/2022 05:37:34	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Steam
2210003828	Northwich	11/10/2022 07:52:50	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2210004768	Congleton	13/10/2022 21:45:32	OtherResidential	Nursing/Care	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2210009530	Chester	26/10/2022 19:23:44	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2210009726	Chester	27/10/2022 08:49:24	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2211008355	Chester	21/11/2022 12:43:50	NonResidential	Other Restaurant/café - (licensed for sale of alcohol)	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2212002554	Chester	08/12/2022 04:09:39	OtherResidential	Hotel/motel	Special Service	Lift Release
2212006380	Chester	17/12/2022 06:57:39	NonResidential	Shopping Centre	Special Service	Flooding
2212007918	Malpas	19/12/2022 16:42:56	Dwelling	Castle	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2301002025	Macclesfield	07/01/2023 15:36:06	NonResidential	Hospital	Special Service	No action (not false alarm)
2301006965	Wilmslow	23/01/2023 16:03:14	NonResidential	Purpose built office	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2301008575	Chester	27/01/2023 19:03:23	OtherResidential	Children's	False Alarm	Malicious False Alarm >> Activation of fire call point/alarm
2302001035	Tarporley	04/02/2023 12:26:31	Dwelling	Castle	Special Service	Assist other agencies
2302004203	Chester	12/02/2023 22:41:52	Dwelling	House - single occupancy	False Alarm	Good Intent false alarm >> Special Service >> Not required
2302007909	Tarporley	23/02/2023 06:39:45	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> System: other >> Faulty
2302009404	Bollington	27/02/2023 02:00:33	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2302009502	Macclesfield	27/02/2023 11:30:42	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2303000421	Macclesfield	02/03/2023 09:55:47	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2303004624	Poynton	13/03/2023 21:53:27	Dwelling	Stately Home	Fire	Primary Fire - Accidental cause
2303007985	Macclesfield	23/03/2023 16:38:09	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2303009257	Macclesfield	27/03/2023 14:20:13	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2304000472	Wilmslow	02/04/2023 11:41:05	NonResidential	Pub/wine bar/bar	Fire	Chimney Fire - Accidental cause
2304002423	Congleton	07/04/2023 07:01:51	OtherResidential	Hotel/motel	Fire	Primary Fire - Accidental cause
2304003004	Macclesfield	08/04/2023 16:30:46	NonResidential	Church/Chapel	False Alarm	Malicious False Alarm >> By phone
2304004096	Chester	11/04/2023 12:36:52	NonResidential	Department Store	Special Service	Lift Release
2304005038	Congleton	14/04/2023 04:18:41	OtherResidential	Nursing/Care	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2304005126	Macclesfield	14/04/2023 12:15:29	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2304005327	Alsager	14/04/2023 18:48:25	NonResidential	Pub/wine bar/bar	Fire	Chimney Fire - Accidental cause
2304007534	Macclesfield	20/04/2023 09:04:38	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2304007690	Chester	20/04/2023 16:44:54	NonResidential	Bank/Building Society	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2304008301	Macclesfield	21/04/2023 22:55:33	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2304009095	Congleton	24/04/2023 13:35:25	NonResidential	Other private non-residential building	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2304009925	Macclesfield	26/04/2023 11:17:03	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2304011669	Knutsford	30/04/2023 19:27:44	NonResidential	Other Restaurant/café - (licensed for sale of alcohol)	Special Service	No action (not false alarm)
2305000546	Knutsford	02/05/2023 12:37:44	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> External factors >> Power surge
2305005889	Macclesfield	15/05/2023 01:23:31	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2305007473	Sandbach	18/05/2023 21:26:09	Dwelling	Up to 2 storeys	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2305008547	Stockton Heath	21/05/2023 16:03:42	NonResidential	Secondary school	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Dust
2305008904	Macclesfield	22/05/2023 11:43:53	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2306002965	Knutsford	07/06/2023 02:10:44	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2306004626	Chester	10/06/2023 12:06:39	NonResidential	Other Restaurant/café - (licensed for sale of alcohol)	Fire	Primary Fire - Accidental cause

Listed Buildings

Inc No	Station Area	Time Of Call	Property Category	Property Type	Incident Category	Incident Type
2306005734	Chester	12/06/2023 11:18:13	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2306006810	Chester	13/06/2023 19:02:02	NonResidential	Single shop	Special Service	Effecting entry/exit
2306011529	Macclesfield	22/06/2023 16:12:38	OtherResidential	Nursing/Care	Special Service	Removal of objects from people
2307000573	Congleton	02/07/2023 16:08:19	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2307001456	Stockton Heath	04/07/2023 20:48:28	NonResidential	Sports and Social club	Fire	Derelict Building Fire - Deliberate cause
2307003008	Chester	08/07/2023 14:01:46	NonResidential	Department Store	Special Service	Lift Release
2307003092	Chester	08/07/2023 17:31:48	OtherResidential	Hotel/motel	Special Service	Flooding
2307004143	Macclesfield	11/07/2023 09:20:23	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2307005394	Lymm	14/07/2023 11:28:23	OtherResidential	Hotel/motel	False Alarm	Good Intent false alarm >> Special Service >> Not required
2307009950	Ellesmere Port	26/07/2023 11:40:23	NonResidential	Chemicals	Special Service	Hazardous Materials incident
2308000864	Chester	03/08/2023 10:15:38	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2308004721	Chester	13/08/2023 06:06:08	Dwelling	Up to 3 storeys	False Alarm	Good Intent false alarm >> Special Service >> Not required
2308004727	Chester	13/08/2023 06:29:09	Dwelling	4 to 9 storeys	False Alarm	Good Intent false alarm >> Special Service >> Reported incident/Location not found
2308006011	Malpas	16/08/2023 13:27:37	Dwelling	Castle	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2308007203	Congleton	19/08/2023 10:29:14	OtherResidential	Nursing/Care	Fire	Derelict Building Fire - Deliberate cause
2308010169	Chester	26/08/2023 23:21:15	OtherResidential	Hotel/motel	Special Service	Flooding
2308010475	Holmes Chapel	27/08/2023 22:17:53	OtherResidential	Hotel/motel	Special Service	Lift Release
2308011510	Chester	30/08/2023 20:06:06	NonResidential	Museum	False Alarm	Good Intent false alarm >> Fire >> Controlled burning
2309001227	Chester	04/09/2023 05:12:12	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2309002518	Knutsford	07/09/2023 05:43:01	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2309005673	Winsford	14/09/2023 17:48:27	OtherResidential	Children's	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2309008080	Wilmslow	20/09/2023 19:27:44	OtherResidential	Hotel/motel	Fire	Derelict Building Fire - Deliberate cause
2309008679	Macclesfield	22/09/2023 11:45:15	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2309010120	Chester	26/09/2023 15:38:11	Dwelling	Up to 3 storeys	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Damaged
2309010310	Macclesfield	26/09/2023 23:50:50	NonResidential	Hospital	False Alarm	Good Intent false alarm >> Fire >> Steam
2310002103	Malpas	06/10/2023 14:22:58	Dwelling	Castle	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2310002848	Chester	08/10/2023 16:11:33	NonResidential	Department Store	Special Service	Making Safe (not RTC)
2310004395	Macclesfield	12/10/2023 12:07:59	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2310005081	Holmes Chapel	14/10/2023 01:23:13	OtherResidential	Hotel/motel	Special Service	Lift Release
2310005490	Macclesfield	15/10/2023 09:04:13	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2310005496	Runcorn	15/10/2023 09:12:02	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2310005688	Macclesfield	15/10/2023 18:49:31	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2310006094	Macclesfield	16/10/2023 18:30:16	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Smoking
2310008693	Congleton	22/10/2023 18:43:41	OtherResidential	Nursing/Care	Special Service	Other assistance to police/ambulance
2310008870	Knutsford	23/10/2023 08:47:47	NonResidential	Golf Clubhouse	Fire	Primary Fire - Accidental cause
2310009225	Chester	24/10/2023 02:00:25	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2311002870	Chester	07/11/2023 12:15:57	OtherResidential	Hotel/motel	False Alarm	Good Intent false alarm >> Fire >> Smoking chimney
2311003439	Chester	08/11/2023 23:43:59	NonResidential	Cinema	Special Service	Lift Release
2311005122	Congleton	13/11/2023 03:13:22	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2311005313	Chester	13/11/2023 13:23:39	NonResidential	Single shop	Special Service	Making Safe (not RTC)
2311006162	Nantwich	15/11/2023 12:38:58	Dwelling	Up to 3 storeys	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2311006643	Runcorn	16/11/2023 19:58:54	NonResidential	Pub/wine bar/bar	Fire	Derelict Building Fire - Deliberate cause
2311007051	Chester	17/11/2023 21:11:06	NonResidential	Converted office	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2311011029	Poynton	29/11/2023 06:11:45	OtherResidential	Nursing/Care	Special Service	Other assistance to police/ambulance
2312000006	Ellesmere Port	01/12/2023 00:54:26	Dwelling	Self contained Sheltered Housing	False Alarm	Good Intent false alarm >> Fire >> Fumes/heat haze

Listed Buildings

Inc No	Station Area	Time Of Call	Property Category	Property Type	Incident Category	Incident Type
2312000862	Knutsford	03/12/2023 07:40:21	NonResidential	Other Restaurant/café - (licensed for sale of alcohol)	Special Service	Flooding
2312002500	Chester	07/12/2023 13:51:44	NonResidential	Theatre	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2312003639	Chester	10/12/2023 11:12:23	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2312003946	Chester	11/12/2023 10:10:04	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2312007437	Macclesfield	21/12/2023 09:05:29	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2312009211	Bollington	27/12/2023 04:26:30	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2312009374	Bollington	27/12/2023 15:23:40	OtherResidential	Hotel/motel	Special Service	Effecting entry/exit
2312010165	Warrington	30/12/2023 07:00:51	NonResidential	Theatre	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Smoke Cloak
2401002829	Chester	09/01/2024 09:15:11	NonResidential	Dentist	Special Service	Hazardous Materials incident
2401003811	Chester	12/01/2024 02:44:39	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2401006888	Chester	20/01/2024 18:11:10	OtherResidential	Hotel/motel	Special Service	Lift Release
2401008944	Northwich	26/01/2024 00:01:22	Dwelling	House - single occupancy	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2401010029	Macclesfield	29/01/2024 10:41:34	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> External factors >> Smoke from elsewhere (not at location)
2401010037	Northwich	29/01/2024 11:06:52	Dwelling	House - single occupancy	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2402000537	Northwich	02/02/2024 14:51:03	OtherResidential	Nursing/Care	Special Service	Removal of objects from people
2402000691	Wilmstow	03/02/2024 01:24:49	NonResidential	Purpose built office	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2402001329	Chester	05/02/2024 03:27:24	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Dust
2402002430	Macclesfield	08/02/2024 11:36:15	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Dust
2402005769	Chester	18/02/2024 15:19:49	NonResidential	Converted office	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2402006973	Macclesfield	22/02/2024 05:36:04	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: other >> Faulty
2402007013	Macclesfield	22/02/2024 09:11:08	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2402007388	Macclesfield	23/02/2024 12:20:45	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: other >> Faulty
2402008326	Warrington	26/02/2024 10:24:38	NonResidential	Converted office	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2403003003	Macclesfield	09/03/2024 14:38:42	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2403007915	Chester	23/03/2024 15:49:22	NonResidential	Department Store	Special Service	Lift Release
2403007955	Sandbach	23/03/2024 19:09:21	NonResidential	Single shop	False Alarm	Good Intent false alarm >> Fire >> Steam
2403010455	Chester	30/03/2024 17:35:07	OtherResidential	Hotel/motel	Special Service	Lift Release
2404001750	Chester	06/04/2024 03:36:46	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2404001975	Knutsford	06/04/2024 20:13:54	OtherResidential	Nursing/Care	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2404003440	Macclesfield	11/04/2024 07:44:50	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Dust
2404005174	Winsford	15/04/2024 16:56:35	OtherResidential	Children's	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Water intrusion
2404006887	Chester	19/04/2024 19:05:54	OtherResidential	Hotel/motel	Special Service	Lift Release
2404008757	Chester	24/04/2024 18:07:53	NonResidential	Underground	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2405006433	Macclesfield	16/05/2024 08:35:44	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2405006454	Macclesfield	16/05/2024 09:32:15	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2405007497	Chester	18/05/2024 19:29:07	OtherResidential	Hotel/motel	False Alarm	Good Intent false alarm >> Special Service >> Not required
2405008336	Widnes	20/05/2024 16:35:18	Dwelling	Up to 3 storeys	Special Service	Other rescue/release of persons
2405010360	Nantwich	25/05/2024 07:14:19	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Other
2405012469	Macclesfield	30/05/2024 19:53:42	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Steam
2406001252	Macclesfield	04/06/2024 13:40:53	OtherResidential	Nursing/Care	Special Service	Removal of objects from people
2406003294	Macclesfield	09/06/2024 18:23:25	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2406005307	Congleton	14/06/2024 21:19:08	OtherResidential	Boarding School accommodation	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2406010283	Congleton	26/06/2024 22:02:26	Dwelling	House - single occupancy	Special Service	No action (not false alarm)
2406010505	Northwich	27/06/2024 13:26:37	OtherResidential	Nursing/Care	Special Service	Removal of objects from people
2407000051	Congleton	01/07/2024 07:52:50	NonResidential	Dentist	Fire	Primary Fire - Accidental cause

Listed Buildings

Inc No	Station Area	Time Of Call	Property Category	Property Type	Incident Category	Incident Type
2407002249	Knutsford	07/07/2024 01:44:33	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: other >> Faulty
2407003746	Knutsford	11/07/2024 02:33:38	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2407004936	Chester	14/07/2024 08:19:07	OtherResidential	Boarding School accommodation	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2407005338	Macclesfield	15/07/2024 07:44:46	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2408001745	Knutsford	05/08/2024 09:29:25	OtherResidential	Nursing/Care	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2408003088	Chester	08/08/2024 11:02:55	NonResidential	Converted office	False Alarm	Good Intent false alarm >> Fire >> Other
2408010829	Malpas	28/08/2024 00:55:34	OtherResidential	Nursing/Care	False Alarm	Fire alarm due to Apparatus >> Human >> Cooking/burnt toast
2408012073	Chester	31/08/2024 12:25:36	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2409001483	Northwich	04/09/2024 16:05:36	Dwelling	House - single occupancy	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2409004091	Macclesfield	11/09/2024 16:18:30	NonResidential	Hospital	Fire	Primary Fire - Accidental cause
2409005517	Chester	15/09/2024 00:10:19	NonResidential	Single shop	False Alarm	Malicious False Alarm >> Activation of fire call point/alarm
2409005906	Macclesfield	16/09/2024 09:25:46	NonResidential	Converted office	False Alarm	Fire alarm due to Apparatus >> Human >> Testing
2409006199	Chester	17/09/2024 01:21:08	Dwelling	Self contained Sheltered Housing	Special Service	No action (not false alarm)
2409006216	Knutsford	17/09/2024 04:27:22	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2409006541	Ellesmere Port	17/09/2024 21:28:19	NonResidential	Pub/wine bar/bar	Special Service	Other rescue/release of persons
2409006699	Chester	18/09/2024 09:47:50	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Poor maintenance
2409008282	Chester	21/09/2024 22:15:13	NonResidential	Other Restaurant/café - Not known if - licensed	Special Service	Making Safe (not RTC)
2409008664	Macclesfield	23/09/2024 07:49:16	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2409010425	Macclesfield	28/09/2024 01:43:51	OtherResidential	Hotel/motel	False Alarm	Malicious False Alarm >> Activation of fire call point/alarm
2409010597	Chester	28/09/2024 15:31:12	NonResidential	Single shop	Special Service	Lift Release
2409011266	Macclesfield	30/09/2024 08:45:49	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2410001304	Bollington	04/10/2024 09:02:34	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2410001720	Powey Lane	05/10/2024 08:42:05	OtherResidential	Nursing/Care	Special Service	Other assistance to police/ambulance
2410005466	Audlem	15/10/2024 13:12:57	Dwelling	Stately Home	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Dust
2410005723	Wilmslow	16/10/2024 00:06:38	OtherResidential	Hotel/motel	Fire	Primary Fire - Accidental cause
2410009052	Knutsford	23/10/2024 17:26:42	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2410009741	Macclesfield	25/10/2024 08:37:45	NonResidential	Hospital	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2410010368	Bollington	26/10/2024 20:13:29	NonResidential	Town Hall	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2411002010	Chester	04/11/2024 23:45:41	OtherResidential	Hotel/motel	Special Service	Lift Release
2411007138	Runcorn	15/11/2024 12:03:49	Dwelling	Up to 3 storeys	Special Service	Hazardous Materials incident
2411009267	Chester	21/11/2024 03:11:55	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Chemicals/aerosols
2411009421	Chester	21/11/2024 12:01:25	NonResidential	Pub/wine bar/bar	Fire	Chimney Fire - Accidental cause
2411010114	Macclesfield	23/11/2024 01:06:18	NonResidential	Hospital	Special Service	Removal of objects from people
2411011005	Macclesfield	24/11/2024 10:42:54	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Steam
2411011629	Chester	26/11/2024 00:25:51	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2412002339	Chester	07/12/2024 13:04:02	NonResidential	Single shop	Special Service	Spills and Leaks (not RTC)
2412005978	Macclesfield	16/12/2024 21:16:52	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Smoking
2412006642	Chester	18/12/2024 14:52:13	NonResidential	Medical/health centre	False Alarm	Good Intent false alarm >> Fire >> Reported incident/Location not found
2412008482	Chester	23/12/2024 23:43:56	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> System: other >> Faulty
2501005046	Macclesfield	11/01/2025 23:31:46	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2501005601	Nantwich	13/01/2025 15:38:10	NonResidential	Church/Chapel	False Alarm	Good Intent false alarm >> Fire >> Reported incident/Location not found
2501010401	Chester	26/01/2025 03:59:51	Dwelling	Up to 2 storeys	Special Service	Other assistance to police/ambulance
2501012007	Chester	30/01/2025 15:08:31	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Steam
2502006679	Warrington	19/02/2025 14:05:01	NonResidential	Police station	Special Service	Assist other agencies
2502007374	Tarpoley	21/02/2025 08:04:39	NonResidential	Pub/wine bar/bar	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Minute animals (e.g. Thrips and Midges)

Listed Buildings

Inc No	Station Area	Time Of Call	Property Category	Property Type	Incident Category	Incident Type
2502009399	Macclesfield	26/02/2025 09:31:00	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2503006366	Chester	15/03/2025 11:57:16	NonResidential	Single shop	Fire	Primary Fire - Accidental cause
2503008180	Macclesfield	19/03/2025 07:01:31	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Unknown
2503009921	Chester	22/03/2025 02:27:41	Dwelling	Up to 3 storeys	Special Service	Other assistance to police/ambulance
2503010967	Macclesfield	24/03/2025 16:56:59	NonResidential	Hospital	False Alarm	Good Intent false alarm >> Fire >> Fumes/heat haze
2503012027	Chester	27/03/2025 09:20:32	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Smoke Cloak
2504008899	Macclesfield	16/04/2025 10:15:38	NonResidential	Hospital	False Alarm	Fire alarm due to Apparatus >> Unknown
2504008963	Macclesfield	16/04/2025 13:20:15	NonResidential	Hospital	False Alarm	Good Intent false alarm >> Fire >> Overheating appliance
2504009324	Powey Lane	17/04/2025 12:33:37	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2504010863	Knutsford	21/04/2025 10:32:55	Dwelling	House - single occupancy	False Alarm	Fire alarm due to Apparatus >> Human >> Accidentally/carelessly set off
2504011571	Knutsford	22/04/2025 23:08:46	NonResidential	Pub/wine bar/bar	Fire	Primary Fire - Accidental cause
2504015254	Chester	30/04/2025 19:48:33	Dwelling	Up to 3 storeys	Special Service	Effecting entry/exit
2505001283	Warrington	03/05/2025 14:36:26	NonResidential	Church/Chapel	Fire	Derelict Building Fire - Deliberate cause
2505002438	Warrington	05/05/2025 23:48:22	Dwelling	Up to 2 storeys	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Damaged
2505005447	Holmes Chapel	11/05/2025 08:28:50	NonResidential	Pub/wine bar/bar	False Alarm	Good Intent false alarm >> Fire >> Overheating appliance
2505008488	Chester	16/05/2025 11:02:29	NonResidential	Pre School/nursery	False Alarm	Good Intent false alarm >> Fire >> Overheating light/fitting
2505008987	Nantwich	16/05/2025 23:26:42	OtherResidential	Hotel/motel	False Alarm	Fire alarm due to Apparatus >> Contaminants >> Steam
2505010207	Ellesmere Port	18/05/2025 19:25:54	Dwelling	Up to 3 storeys	False Alarm	Good Intent false alarm >> Special Service >> Not required
2505015046	Bollington	28/05/2025 19:16:31	OtherResidential	Hotel/motel	Special Service	Lift Release
2505015974	Chester	31/05/2025 08:25:09	NonResidential	Single shop	False Alarm	Fire alarm due to Apparatus >> System: smoke alarm >> Faulty
2505016155	Nantwich	31/05/2025 16:32:07	NonResidential	Single shop	Special Service	Making Safe (not RTC)